

PREGLED POSTUPKA #79351

1 PODACI O NARUČIOCU

Naziv naručioca	ZETA ENERGY DOO
PIB	02794624
E-mail	jefimija@zeta-energy.me
Telefon	020/813-313
Internet adresa	www.zeta-energy.me
Fax	020/813-313
Adresa	Glavica bb
Grad	Danilovgrad
Poštanski broj	81410

2 OSNOVNI PODACI

Opis predmeta javne nabavke	Rezervni djelovi za male hidroelektrane
Status	U toku
Vrsta predmeta	Robe
Vrsta postupka	Jednostavna nabavka
Službenik za javne nabavke	Mirko Bjelica
Kontakt	Mirko Bjelica 067556412
Datum objave	30.09.2024. 12:00
Napomena	-

3 FAZE U POSTUPKU

Vrsta faze	Opis	Početak podnošenja	Kraj podnošenja	Datum otvaranja	Status
Zahtjev za podnošenje ponuda	Zahtjev za dostavljanje ponuda	30.09.2024 12:00	04.10.2024 12:00	04.10.2024 12:00	U toku

4 DODATNE INFORMACIJE

Predmet javne nabavke se nabavlja	kao cjelina
Posebni oblici javne nabavke	
Okvirni sporazum	Ne
Dinamički sistem nabavki	Ne
Elektronska aukcija	Ne
Elektronski katalog	Ne
Nabavka se sprovodi kao	
Zajednička nabavka	Ne
Centralizovana nabavka	Ne

5 STAVKE PLANA

Godina	Opis	Vrijednost nabavke	Vrijednost PDV	Okvirni sporazum	Vrijednost OS	Vrijednost PDV OS	Vrsta postupka
2024	ZETA ENERGY DOO Rezervi djelovi za elektrane 31221000 - Električni releji 38421110 - Mjerači protoka 42131100 - Ventili definisani prema funkciji	10.720,00 EUR	2.251,20 EUR	-	-	-	Jednostavna nabavka

6 USLOVI ZA UČEŠĆE U POSTUPKU I ZAHTJEVI U POGLEDU NAČINA IZVRŠAVANJA PREDMETA NABAVKE

Opis	Tip uslova / zahtjeva
30 dana od dana zaključenja ugovora	Rok izvršenja ugovora
Kancelarije Zeta-Energy Glavica bb Danilovgrad	Mjesto izvršenja ugovora
30 dana od dana ispostavljanja fakture	Rok plaćanja
virmanski uz navodjenje odgovarajućeg poziva na broj računa i broj ugovora za predmetnu nabavku	Način plaćanja
12 mjeseci od dana isporuke robe. U slučaju konstatovanja nedostataka i uočavanja grešaka u toku garantnog roka, Naručilac će o tome odmah pisanim putem obavijestiti izabranog ponudjača koji je dužan da u roku od 5 dana od dana prijema obavještenja o svom trošku otkloni nedostatke.	Garantni rok
originalno pakovanje proizvoda sa utisnutom standardnom deklaracijom	Pakovanje
Izabrani ponudjač se obavezuje da robe isporuči u svemu prema uslovima iz Zahtjeva Naručioca i izabrane ponude koja će biti sastavni dio Ugovora o javnoj nabavci, u skladu sa pravilima o transportu i čuvanju robe. Izabrani ponudjač je dužan da prije isporuke pisanim putem obavijesti Naručioca o terminu isporuke, odnosno dostavi skeniranu kopiju otpremnice potpisanu od ovlašćenog lica za robu koja je predmet Ugovora. isporuka će se smatrati izvršenom kada Komisija naručioca u mjestu isporuke obavi kvalitativni i količinski prijem robe, što se potvrđuje zapisnikom o primopredaji robe. ako prilikom primopredaje, se utvrdi da roba koju je izabrani ponudjač isporučio ima nedostataka u kvalitetu ili količini, izabrani ponudjač se obavezuje da odmah preduzme aktivnosti kako bi otklonio nedostatke istaknute od strane Naručioca. Ukoliko se poslije primopredaje robe pokaže da roba ima neki nedostatak koji se nije mogao otkriti uobičajenim pregledom prilikom preuzimanja robe (skriveni nedostatak), Naručilac će o tome bez odlaganja obavijestiti Isporučioca kako bi iste otklonio.	Uslovi za primopredaju

Način utvrđivanja ekvivalentnosti: u slučaju da ponudjač nudi ekvivalent, dužan je ponuditi robu koja je ekvivalent robi navedenoj u tehničkoj specifikaciji, uz podnošenje potvrda proizvođača robe koju nudi da ponudjeni djelovi odgovaraju geometrijski i funkcionalno (u potvrdi navesti kataloške brojeve djelova za koje vazi potvrda)	Drugi uslovi
Uz ponudu se dostavlja izjava ponuđača o ispunjenosti uslova utvrđenih zahtjevom i nepostojanju sukoba interesa, potpisana od strane ovlašćenog lica ponuđača, data na Obrascu 2.	Drugi uslovi

7 KRITERIJUMI ZA IZBOR NAJPOVOLJNIJE PONUDE

Opis
Cijena
kreterijum za izbor najpovoljnije ponude je najniža ponudjena cijena

8 PREDMET NABAVKE

Procijenjena vrijednost nabavke: 8.800,00 EUR

TEHNIČKA SPECIFIKACIJA PREDMETA NABAVKE

	Opis predmeta nabavke	Bitne karakteristike predmeta nabavke	Količina
1	Plovak za potopne pumpe	Plovak za potopne pumpe sa kabelom dužine 10 metara	4,00 kom
2	Magnetostruktivni linearni senzori položaja	Senzor: Magnetostrictive Sensors - BALLUFF (ili ekvivalent) BTL7-A501-M0100-P-S32 Order Code: BTL1FHR Magnet: Mechanical Accessories BTL5-F-2814-1S Order Code: BAM014H Osovinica-ruka: Fastening Technology BTL2-GS10-0350-A Order Code: BAM00ZC	1,00 set
3	Sonda za očitavanje nivoa vode	UWT Capanivo CN 8100 - A01E0A1Q2A Kabel dužine od 9 metara do 12 metara (ili ekvivalent)	2,00 kom
4	Hidraulični ventil brzog zatvaranja	Hidraulični ventil brzog zatvaranja sa senzorom Ventil: 4WMR6 D32/MA Senzor: CSP - M1 - 01	1,00 set
5	Hidraulički špulna ventil	Hidraulični špulni ventil Proizvođač: Hydac - ili ekvivalent Tip: 3WSE 6X H01-24DG/V	2,00 kom

6	Sonda za mjerenje nivoa vode	Proizvođač Nivelco (ili ekvivalent): NPK4430 (1bar, 30m kabel) Dužina kabela: 30 metara	1,00 kom
7	Transmiter protoka	Specifikacija: Proizvođač: Buerkert- Ili ekvivalent Tip: 8036 SE35-0000-0000-R3-A-C-F4-BDN / DC-A Detalji: Prirubnički spoj, DN25; Kućište od nerđajućeg čelika; Viton brtva; 4 ... 20mA izlaz, puls; Totalizator protoka; Napajanje 4..20mA Navedeni transmiter protoka ima sposobnost mjerenja protoka tekućine kroz cjevovod sa prirubničkim spojem DN25, uz omogućavanje kontinualnog izlaza podataka o protoku putem signala 4-20mA, te takođe omogućuje praćenje ukupnog protoka (totalizator).	1,00 kom

8	Zaporni električno-upravljeni ventil	Specifikacija ventila: Proizvođač: Buerkert ili ekvivalent Model: 8804-BK-3-2-25,0EE-VA-FD12-035-XB-BFI / UC Tip ventila: Električni upravljački ventil, kugla Veličina: DN25 (Kvs = 72m³/h) Materijal: Kućište od nerđajućeg čelika, teflonska brtva Priključak: Prirubnički priključak Pogon: Električni pogon tipa 3003 sa ulazom 4 ... 20mA Ovaj električno-upravljeni ventil proizvođača Buerkert modela 8804-BK-3-2-25,0EE-VA-FD12-035-XB-BFI / UC je ventil kuglastog oblika veličine DN25 s kapacitetom protoka (Kvs) od 72m³/h. Izrađen je s kućištem od nerđajućeg čelika i teflonskom brtvom te ima prirubnički priključak. Opremljen je električnim pogonom tipa 3003 s ulazom 4 ... 20mA za upravljanje ventilom.	1,00 kom
9	Elektromagnetni prekidač / Electromagnetic switch	Proizvođač: Schneider-ili ekvivalent Tip: LC1D32 - 220 VAC	2,00 kom
10	PLC	Siemens LOGO 8 ili ekvivalent. Ponuđeni PLC treba da bude kompatibilan sa software-om za programiranje - LOGO Soft Comfort V8.4	3,00 kom
		The LOGO! ili ekvivalent. Ponuđeni modul za proširenje treba da bude kompatibilan sa već ugrađenim Siemens LOGO 8, kao i software-om LOGO Soft Comfort V8.4! The DM16 24 Expansion Module is a basic module without a display that serves as an expansion unit for the Siemens LOGO! PLC system. Here are the specifications: - Product Name: LOGO! DM16 24 Expansion Module - Type: Expansion module for Siemens LOGO! PLC system	

11	PLC	- **Display:** Does not have an integrated display - **Digital Inputs:** 8 digital inputs (DI) - **Digital Outputs:** 8 digital outputs (DO) - **Memory Words:** 4 memory words (MW) This expansion module is designed to be connected to a base unit or another expansion module within the LOGO! system. It extends the input and output capabilities of the PLC, allowing for additional digital inputs and outputs to be integrated into the automation setup. The DM16 24 Expansion Module provides 8 digital inputs and 8 digital outputs, allowing for more devices or sensors to be controlled and monitored within the automation system. With 4 memory words available, it offers storage for data or control information within the PLC. The absence of a display in this module means that any programming or monitoring of its functions would typically be done through the central programming interface of the LOGO! system, which might include software like LOGO! Soft Comfort. This module is suitable for expanding the control capabilities of the Siemens LOGO! PLC system in various applications, where additional digital inputs and outputs are required for the automation process.	2,00 kom
----	-----	--	----------

12	PLC	The LOGO! ili ekvivalent. Ponuđeni modul za proširenje treba da bude kompatibilan sa već ugrađenim Siemens LOGO 8, kao i sa software-om LOGO Soft Comfort V8.4! The AM2 AQ is an expansion module designed to provide analog output functionality for the Siemens LOGO! PLC system. Here are the specifications: - Product Name: LOGO! AM2 AQ Expansion Module - Type: Analog output expansion module for Siemens LOGO! PLC system - Analog Outputs: 2 analog outputs (2AQ) - Voltage Output Range: 0-10V - Current Output Range: 0/4-20mA This expansion module enables the PLC system to generate analog output signals. It offers two analog outputs, allowing voltage output in the range of 0-10V or current output in the range of 0/4-20mA. These outputs can be utilized to interface with various analog devices or control systems requiring precise voltage or current signals. The LOGO! AM2 AQ module is typically used in applications where analog control or regulation is necessary, such as controlling motors, valves, or other devices that require variable voltage or current inputs.	1,00 kom
----	-----	---	----------